

This document is a translation of the original document, written in Spanish for Comisión Estatal de Servicios Públicos de Tijuana (CESPT), the water and wastewater operating agency for the municipalities of Tijuana and Playas de Rosarito, Baja California, Mexico.

Contents

Appendices Only

<i>Appendix A</i>	Documents Report
<i>Appendix B</i>	Methodology of Economic Factors and Activity
<i>Appendix C</i>	Description of the Potable Water System Districts
<i>Appendix D</i>	List of Standpipes in Operation
<i>Appendix E</i>	Structures connected to the Telemetry System
<i>Appendix F</i>	List of Regulation Tanks
<i>Appendix G</i>	List of Pumping Stations
<i>Appendix H</i>	Main Problems Observed with the Potable Water System
<i>Appendix I</i>	Potable Water System
<i>Appendix J</i>	Wastewater System
<i>Appendix K</i>	Sustainable Development Criteria
<i>Appendix L</i>	Methodology used for the Population Projections
<i>Appendix M</i>	Population and Land Use Projections Tables and Figures
<i>Appendix N</i>	Economic Growth Forecast
<i>Appendix O</i>	Demand Model
<i>Appendix P</i>	Master Plan Assumptions Concerning the Public Law 106-457
<i>Appendix Q</i>	Pipelines with Insufficient Capacity in Maximum Flow Conditions (2001)
<i>Appendix R</i>	Methodology Used to Estimate Costs (English Translation Forthcoming)
<i>Appendix S</i>	Methodology Used in the Preliminary Estimation of the Potential Environmental Impact (English Translation Forthcoming)

APPENDIX G

List of Pumping Stations

Appendix G

List of pumping stations

The Obrera Station has three 400 HP pumps; two of them operate continuously and the third is in reserve. The Morelos Station has two 400 HP pumps, one in continuous operation and the other in reserve. Finally, the Reforma Station has three 200 HP pumps; two of them operate continuously and the third is in reserve. In the Reforma Station, has two 60 HP pumps; one operating and the other in reserve. The three main pumping stations have a total combined pumping capacity of 2,720 HP.